

PTC

Thermal protection device for electric units

3 ptc input channels, 3 output relays



USER'S MANUAL

ALMA Elettronica S.r.l.

**The ALMA Elettronica S.r.l. company can modify the device and
this manual without notice**

Manual Code M0012

Index

Figure Index	4
Introduction	5
<i>Device Overview</i>	5
Technical specifications	6
<i>Cutions</i>	7
Installation Instructions	7
<i>Device and accessories description</i>	7
Frontal panel	7
Back panel and accessories	8
<i>Mechanical installation</i>	8
<i>Electrical connections</i>	9
Power Supply	9
Relays outputs connection	9
Probes connection	9
Instructions for use	10
<i>Temperature measurement</i>	10
<i>Led</i>	10
Buttons	10
Delay setting on channel A1	11
Deactivation of channel A1	11
Relays test	11
Damaged probe test deactivation	11
Solution of problems	12
Guarantee conditions	13
Appendix A	14

Figure index

[illegible]

Introduction

We thank you for your choice to purchase the electronic device for temperature monitoring *PTC*.

This manual explains how to install and use it.

For a useful usage of this manual, we suggest you to read it standing near to the *PTC* device to directly verify the instructions. We suggest indeed to keep the manual for future use.

Device Overview

The *PTC* electronic device comes into being to satisfy the requirements of the insulated resin or dry type transformers users and installers.

In details the device characteristics are:

- **3 analog input channels** for resistive probes Ptc to measure 3 temperatures with 3 series of probes: A1 series, A2 series and A3 series (figure 1).
- **Led** to visualize the alarms and the fan deactivation alarms.
- **2 buttons** to manage the setup parameters.
- **Non volatile data storage** of the user's parameters.
- **3 relays output** channels to perform three alarm signalling levels on the measured temperatures. The three alarm levels can be used to control the transformer's ventilation, to activate external alarm signalling (as lights and sirens) and to control the protection unhook of the electric unit from the line.

The system performs useful setup of delay parameters and an easy activation of the relays test.




Figure 1

Technical specifications

Power supply

- nominal line voltage and frequency: $24 \div 380$ Vcc and $24 \div 230$ Vac at $40 \div 60$ Hz
- maximum line voltage $24 \div 390$ Vcc and $24 \div 265$ Vac
- Vcc with reversible polarity
- Maximum power absorption 3 VA
- Protection against electrical and magnetic noises

Inputs

- 3 analog input channels for Ptc probes
- connection with removable terminals for wires of $1,5 \text{ mm}^2$ section and capacity of 8A/250 Vac
- detection for broken or not connected probes
- input channels protected against electromagnetic noises and spikes

Outputs

- 3 output relays with contacts capacity of 5A with 250Vac
 - one relay for the series A1 (for fan control)
 - one relay for the series A2 (pre-alarm) and for probe fault or working anomaly signaling (general alarm)
 - one relay for the series A3 (unhook of the electrical unit)
- output connection with removable terminals for wire of $1,5 \text{ mm}^2$ section and capacity of 8A/250 Vac

Device dimensions

- frontal dimension 48 mm x 96 mm compliance with DIN 43700 requirements. Device length of 130 mm with rear terminals
- assembling on the front of the electric panel
- Panel cut-out 44 mm x 92 mm
- ABS self-extinguishing container
- Frontal panel in anti-scratch poly-carbonate with keyboard and signal leds

Performances

- Probe self-diagnostics
- Operating temperature range from -20°C to 50°C
- Humidity lower than 95% no-condensing
- Compliance with CE requirement
- User data storage for 10 years without power supply
- Device functionality self-diagnostic
- Alarm signal for working anomalies

Displaying and data management

- 3 leds indicating alarm levels
- 1 led indicating working anomalies or probe fault
- 5 leds to visualize the delay set on A1 series alarm
- user data programming by membrane keypad

Cautions

- avoid power supply out of the device nominal range
- use shielded cables for the probes
- avoid the device working in room with conditions out of the nominal ones previously reported and in particular in presence of condensing humidity.

Installation Instructions


For a right operation, the *PTC* device has to be installed compliance to the requirements reported in the Technical Specifications paragraph.

The device provides fixing accessories and removable terminals for electrical connections.

Device and accessories description

Figure 2 represents a scheme of the device.

Frontal Panel




Front view

Figure 2

- Damaged or not connected probe
6. Led indicating the operation state of the device

Back view and accessories

1. Connector for probes connection
2. Connector for relays output
3. Connector for power supply
4. Removable terminals for wiring harness
5. Clips for the device clamping



Rear view and accessories

Figure 3

Mechanical Installation

The PTC device provides a black self-extinguishing PPO container for the assembly. The device dimensions are compliance to the standard of DIN 43700: 48 x 96 mm section and a maximum depth of 105 mm.

The dimensions of the panel perforation are 44 x 92 mm. Assembly is done using




Figure 4

clamps provided with the device. See figure 4.

Electrical Connections

All connections are made with the separable clamps provided with the device for an easy wiring harness. Refer to figure 5 and to the clamp numbering.

Power Supply

The power supply connection is performed connecting the power voltage to the terminals 5 and 7 no matter polarity for Vcc.

The nominal allowed voltages are in the 24 Vcc to the 380 Vcc for direct voltage, and in the 24 Vca to the 230 Vca with 40÷60 Hz frequency for the alternate voltage.




Figure 5

The terminal 6 has to be connected to the ground reference. The device has no fuses inside so it is necessary to provide an external protection.

The device power supply is protected from momentary input over-voltages.

If the PTC device power supply is directly provided by the secondary circuit of a

medium power transformer see **Appendix A** at the end of the manual.

The damage due to a wrong power supply is not covered by guarantee.

Relays output connections

Figure 5 shows the position of the relays when they are not excited (turned off device).

The alarm relays are excited when the set limits are exceeded. The alarm relays of the A2 channel and of the *General Alarm* (🔔) operate in intrinsic security, so that it is excited at the device switchin on, , and is de-activated when the conditions that generate one of the 2 alarms occur (figure 6 shows the relay without any alarm). In this way when the device is turned off you have the non-operating control signalling.




Figure 6

Probes Connections

The analog inputs are compatible with Ptc resistive probes.

Connect the 3 probes series to the device as indicated in figure 5 and place them on the transformer as in figure 1.

Instructions for use

Temperature measurement

On the *PTC* device temperature measurement is done using *Ptc* probes. These probes change their resistance in a very evidently way when a specific temperature threshold called *dNAT* is exceeded. Because different constructors provide probes with different characteristics, in the following table the resistance values that generate alarms on the *PTC* device have been reported.

Resistance value	alarms
$R < 15 \Omega$	under-range error (short circuit probe)
$15 \Omega < R < 1800 \Omega$	no alarm
$1800 \Omega < R < 200 \text{ k}\Omega$	exceeded threshold alarm
$R > 200 \text{ k}\Omega$	over-range error (not connected probe)

When the 1800 W value is exceeded the device activates the channel alarm turning on the respective leds and relays.

With regard to the probe the device signals errors both for too low (short circuit) and too high resistance (not connected probe). The probe's damage is signalled making the respective channel led flash together with the *General Alarm* led (🔴🔊).

A1 channel, commonly used for ventilation, provides a delay on the de-activation of the respective relay that keeps on the fan for a programmable time after the temperature is lower than the threshold. When temperature is under the threshold and the A1 relay is still excited because of the delay, the A1 led flashes at a higher frequency than that of the damaged probe flashing.

The A2 channel relay has an inverse function (see figure 6 and the paragraph *Relays output connections*) because it is shared in common with the *General Alarm* (🔴🔊) that signals a probes' damage or the non function of the device.

Led

Each channel has the respective led on the frontal panel that turns on when the threshold is exceeded.

Also a *General Alarm* (🔴🔊) led is present that turns on when a probe is damaged. Together with this led, the led of the channel with the damaged probe turns on.

There also are 5 leds that visualize in minutes the delay set on the channel A1 alarm (ventilation). The delay times are from 1 to 40 minutes.

Buttons

The device has the 2 buttons 🔄 and ⌚ that perform the following functionalities.

Delay setting on channel A1

Pushing button ⌚ it is possible to set the delay for de-activation of the A1 alarm

(ventilation).

The delay value is indicated by the 5 led horizontal bar (see point 1 of figure 2 at page 7). The delay values go from 1 to 40 minutes. When the delay is of 40 minutes pushing the  button you turn off all the leds of the bar. Pushing the button one more time you restart programming the delay from 1 minute.

Deactivation of channel A1

Push the  button until all the bar leds are turned off. In this case the channel is deactivated and the device will give no error of not connected probe.

Relays test

The device provides a procedure called relays test very useful to installers to verify the wiring harness forcing the relays closure.

This procedure is activated pushing button  during the turning on of the device. The device normally turns on, then cyclically activates the alarms simulating what would happen if each channel exceeded the temperature threshold. The cycle continues until the button is kept pushed.

Damaged probe test deactivation

It is possible to de-activate the damaged probe test on all channels keeping pushed the  button during the turning on of the device. In this way the device gives no alarm for short circuit or not connected probe.

This functionality is signalled during the device switching on making flash three times the horizontal bar leds.

Solution of problems

In this paragraph we give you some suggestions to solve anomalies you can meet using the *PTC* device.

Problem	Solution
The device does not turn on	The device turning on is signalled by the lighting of the led down on the right. Verify the connection to the power supply. Verify there is line voltage. Verify that the power supply values are compliance with those specified in this manual. <i>If the problem persists please contact the device distributor.</i>
The device gives no alarm for damaged probe on none of the channels	Verify that the damaged probe test has not been de-activated. Verification is done turning on the device: if the horizontal bar leds flash for three times the test has been de-activated. See paragraph Deactivation of damaged probe at page 11.
The device gives no alarm for damaged probe on channel A1	Verify that the A1 probe has not been de-activated. The probe is de-activated if no led is turned on the horizontal bar.
No delay is visualized on the horizontal bar	Push the button with the clock to verify if a led excites: this means the A1 channel was de-activated. <i>If the problem persists please contact the device distributor.</i>

Guarantee conditions

The thermal protection *PTC* devices are covered by guarantee for a period of 24 months since the consignment date for anomalies due to production defects.

The guarantee consists in the free repair or substitution of the components that have been damaged in the devices' construction, arrived at our office carriage paid.

The product's guarantee declines in the following cases:

- ! device's damages deriving from negligence, use or installation not compliance with the instructions furnished in the user's manual
- ! wrong power supply
- ! damages due to changes in the line voltage to which the device is connected as in the case of discharges caused by thunderbolts or other external phenomena
- ! tampering with the device
- ! damages due to accidental causes or to negligence
- ! non-payment of the device

The guarantee period is determined on the basis of the serial number written on the device's label so that it has not to be cancelled nor modified.

Parts subjected to wear by use are not covered by guarantee.

Furthermore, removal and re-installation costs are not covered by guarantee, as transport costs and risks and any other direct or indirect cost due to repair of the device you consider damaged.

The constructor declines any responsibility for harms done to persons, animals or things directly or indirectly coming out from a proper or improper use of the device.

The device's repair or substitution is subjected to the unobjectionable constructor's opinion.

When the guarantee period falls the damaged device's repair will involve the debit entry for the damaged components substitution and for the labour.

For any dispute the competent Court is the one of Bologna (Italy).

Appendix A

If the device is directly supplied by the secondary circuit of a medium power transformer it is possible for the device to be crushed by a over-voltage of high intensity. This can occur when you insert the general switch of the installation without load. The phenomenon is particularly evident when the *PTC* is directly supplied by the copper bars of the secondary circuit of the transformer and fixed re-phasing capacitor batteries are present. Provide the device protection inserting an insulating 10 VA transformer (see figure 11).

Damage due to a wrong power supply of the device is not covered by guarantee.




Figure 7

Notes

ALMA Elettronica S.r.l.

via Indipendenza, 13
40069 Zola Predosa (BO)

Italia

tel +39 51 6762544
www.almaelettronica.it